



Chipsmall Limited consists of a professional team with an average of over 10 year of expertise in the distribution of electronic components. Based in Hongkong, we have already established firm and mutual-benefit business relationships with customers from,Europe,America and south Asia,supplying obsolete and hard-to-find components to meet their specific needs.

With the principle of "Quality Parts,Customers Priority,Honest Operation,and Considerate Service",our business mainly focus on the distribution of electronic components. Line cards we deal with include Microchip,ALPS,ROHM,Xilinx,Pulse,ON,Everlight and Freescale. Main products comprise IC,Modules,Potentiometer,IC Socket,Relay,Connector.Our parts cover such applications as commercial,industrial, and automotives areas.

We are looking forward to setting up business relationship with you and hope to provide you with the best service and solution. Let us make a better world for our industry!



## Contact us

Tel: +86-755-8981 8866 Fax: +86-755-8427 6832

Email & Skype: info@chipsmall.com Web: www.chipsmall.com

Address: A1208, Overseas Decoration Building, #122 Zhenhua RD., Futian, Shenzhen, China



## Feed-through terminal block - UT 4-CB OG - 3044610

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (<http://phoenixcontact.com/download>)



Feed-through terminal block, With breakout partition plate in the bridge shaft, nom. voltage: 1000 V, nominal current: 32 A, connection method: Screw connection, number of connections: 2, number of positions: 1, cross section: 0.14 mm<sup>2</sup> - 6 mm<sup>2</sup>, AWG: 26 - 10, width: 6.2 mm, color: orange, mounting type: NS 35/7,5, NS 35/15

RoHS

### Key Commercial Data

|              |               |
|--------------|---------------|
| Packing unit | 50 STK        |
| GTIN         |               |
| GTIN         | 4046356055499 |

### Technical data

#### General

|   |   |
|---|---|
| Note  | Note. In order to use bridges, the panel on the bridge shaft must be removed. |
| Number of positions                             | 1   |
| Number of levels                                | 1   |
| Number of connections                           | 2   |
| Nominal cross section                           | 4 mm <sup>2</sup>   |
| Color   | orange  |
| Insulating material                             | PA  |
| Flammability rating according to UL 94          | V0  |
| Rated surge voltage                             | 8 kV  |
| Degree of pollution                             | 3   |
| Overvoltage category                            | III   |
| Insulating material group                       | I   |
| Maximum power dissipation for nominal condition | 1.02 W  |
| Maximum load current                            | 41 A (with 6 mm <sup>2</sup> conductor cross section)                         |
| Nominal current I <sub>N</sub>                  | 32 A (with 4 mm <sup>2</sup> conductor cross section)                         |
| Nominal voltage U <sub>N</sub>                  | 1000 V  |
| Open side panel                                 | Yes   |

# Feed-through terminal block - UT 4-CB OG - 3044610

## Technical data

### General

|   |   |
|---|---|
| Shock protection test specification   | IEC 60529:2001-02                                   |
| Back of the hand protection   | guaranteed  |
| Finger protection   | guaranteed  |
| Result of surge voltage test  | Test passed   |
| Surge voltage test setpoint   | 9.8 kV  |
| Result of power-frequency withstand voltage test  | Test passed   |
| Power frequency withstand voltage setpoint  | 2.2 kV  |
| Result of the test for mechanical stability of terminal points (5 x conductor connection) | Test passed   |
| Result of bending test  | Test passed   |
| Bending test rotation speed   | 10 rpm  |
| Bending test turns  | 135   |
| Bending test conductor cross section/weight   | 0.14 mm <sup>2</sup> / 0.2 kg                       |
|   | 4 mm <sup>2</sup> / 0.9 kg                          |
|   | 6 mm <sup>2</sup> / 1.4 kg                          |
| Tensile test result   | Test passed   |
| Conductor cross section tensile test  | 0.14 mm <sup>2</sup>                                |
| Tractive force setpoint   | 10 N  |
| Conductor cross section tensile test  | 4 mm <sup>2</sup>                                   |
| Tractive force setpoint   | 60 N  |
| Conductor cross section tensile test  | 6 mm <sup>2</sup>                                   |
| Tractive force setpoint   | 80 N  |
| Result of tight fit on support  | Test passed   |
| Tight fit on carrier  | NS 35   |
| Setpoint  | 1 N   |
| Result of voltage-drop test   | Test passed   |
| Requirements, voltage drop  | ≤ 3.2 mV  |
| Result of temperature-rise test   | Test passed   |
| Short circuit stability result  | Test passed   |
| Conductor cross section short circuit testing   | 4 mm <sup>2</sup>                                   |
| Short-time current  | 0.48 kA   |
| Conductor cross section short circuit testing   | 6 mm <sup>2</sup>                                   |
| Short-time current  | 0.72 kA   |
| Result of thermal test  | Test passed   |
| Proof of thermal characteristics (needle flame) effective duration                        | 30 s  |
| Oscillation, broadband noise test result  | Test passed   |
| Test specification, oscillation, broadband noise  | DIN EN 50155 (VDE 0115-200):2008-03                 |
| Test spectrum   | Service life test category 1, class B, body mounted |
| Test frequency  | f <sub>1</sub> = 5 Hz to f <sub>2</sub> = 150 Hz    |
| ASD level   | 1.857 (m/s <sup>2</sup> ) <sup>2</sup> /Hz          |
| Acceleration  | 0,8 g   |



# Feed-through terminal block - UT 4-CB OG - 3044610

## Technical data

### General

|                                |                                     |
|--------------------------------|-------------------------------------|
| Test duration per axis         | 5 h                                 |
| Test directions                | X-, Y- and Z-axis                   |
| Shock test result              | Test passed                         |
| Test specification, shock test | DIN EN 50155 (VDE 0115-200):2008-03 |
| Shock form                     | Half-sine                           |
| Acceleration                   | 5 g                                 |
| Shock duration                 | 30 ms                               |
| Number of shocks per direction | 3                                   |
| Test directions                | X-, Y- and Z-axis (pos. and neg.)   |

### Dimensions

|                  |         |
|------------------|---------|
| Width            | 6.2 mm  |
| End cover width  | 2.2 mm  |
| Length           | 47.7 mm |
| Height NS 35/7,5 | 47.5 mm |
| Height NS 35/15  | 55 mm   |

### Connection data

|   |                      |
|---|----------------------|
| Connection method   | Screw connection     |
| Connection in acc. with standard  | IEC 60947-7-1        |
| Conductor cross section solid min.  | 0.14 mm <sup>2</sup> |
| Conductor cross section solid max.  | 6 mm <sup>2</sup>    |
| Conductor cross section AWG min.  | 26                   |
| Conductor cross section AWG max.  | 10                   |
| Conductor cross section flexible min.   | 0.14 mm <sup>2</sup> |
| Conductor cross section flexible max.   | 6 mm <sup>2</sup>    |
| Min. AWG conductor cross section, flexible  | 26                   |
| Max. AWG conductor cross section, flexible  | 10                   |
| Conductor cross section flexible, with ferrule without plastic sleeve min.              | 0.14 mm <sup>2</sup> |
| Conductor cross section flexible, with ferrule without plastic sleeve max.              | 4 mm <sup>2</sup>    |
| Conductor cross section flexible, with ferrule with plastic sleeve min.                 | 0.14 mm <sup>2</sup> |
| Conductor cross section flexible, with ferrule with plastic sleeve max.                 | 4 mm <sup>2</sup>    |
| 2 conductors with same cross section, solid min.  | 0.14 mm <sup>2</sup> |
| 2 conductors with same cross section, solid max.  | 1.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded min.                                     | 0.14 mm <sup>2</sup> |
| 2 conductors with same cross section, stranded max.                                     | 1.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min. | 0.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max. | 2.5 mm <sup>2</sup>  |
| 2 conductors with same cross section, stranded, ferrules without plastic sleeve, min.   | 0.14 mm <sup>2</sup> |

# Feed-through terminal block - UT 4-CB OG - 3044610

## Technical data

### Connection data

|   |                     |
|---|---------------------|
| 2 conductors with same cross section, stranded, ferrules without plastic sleeve, max. | 1.5 mm <sup>2</sup> |
| Stripping length  | 9 mm                |
| Internal cylindrical gage   | A4                  |
| Screw thread  | M3                  |
| Tightening torque, min  | 0.6 Nm              |
| Tightening torque max   | 0.8 Nm              |

### Standards and Regulations

|  |               |
|--|---------------|
| Connection in acc. with standard       | IEC 60947-7-1 |
| Flammability rating according to UL 94 | V0            |

### Environmental Product Compliance

|            |   |
|------------|---|
| REACH SVHC | Lead 7439-92-1  |
| China RoHS | Environmentally Friendly Use Period = 50  |
|            | For details about hazardous substances go to tab "Downloads", Category "Manufacturer's declaration" |

## Approvals

### Approvals

---

Approvals

EAC / EAC

---

Ex Approvals

---

### Approval details

|     |   |               |
|-----|---|---------------|
| EAC |  | EAC-Zulassung |
|-----|---|---------------|

|     |   |                          |
|-----|---|--------------------------|
| EAC |  | RU C-<br>DE.A*30.B.01742 |
|-----|---|--------------------------|

---

Phoenix Contact 2018 © - all rights reserved  
<http://www.phoenixcontact.com>

PHOENIX CONTACT GmbH & Co. KG  
Flachmarktstr. 8  
32825 Blomberg  
Germany  
Tel. +49 5235 300  
Fax +49 5235 3 41200  
<http://www.phoenixcontact.com>