

Chipsmall Limited consists of a professional team with an average of over 10 year of expertise in the distribution of electronic components. Based in Hongkong, we have already established firm and mutual-benefit business relationships with customers from, Europe, America and south Asia, supplying obsolete and hard-to-find components to meet their specific needs.

With the principle of "Quality Parts, Customers Priority, Honest Operation, and Considerate Service", our business mainly focus on the distribution of electronic components. Line cards we deal with include Microchip, ALPS, ROHM, Xilinx, Pulse, ON, Everlight and Freescale. Main products comprise IC, Modules, Potentiometer, IC Socket, Relay, Connector. Our parts cover such applications as commercial, industrial, and automotives areas.

We are looking forward to setting up business relationship with you and hope to provide you with the best service and solution. Let us make a better world for our industry!



Contact us

Tel: +86-755-8981 8866 Fax: +86-755-8427 6832

Email & Skype: info@chipsmall.com Web: www.chipsmall.com

Address: A1208, Overseas Decoration Building, #122 Zhenhua RD., Futian, Shenzhen, China







THIS COPY IS PROVIDED ON A RESTRICTED BASIS AND IS NOT TO BE USED IN ANY WAY DETRIMENTAL TO THE INTERESTS OF PANDUIT CORP.

PANDUIT PART NUMBER	WIRE	DIMENSIONS in.		
PREF I X	SIZE AWG	±.02 A	±.01 B DIA.	±.01 C
BS18	22-18	.62 (15.7)	.14 (3.6)	.032
BS14	16-14	.62 (15.7)	.16	.032 (0.81)
BSIO	12-10	.63 (16.0)	.22 (5.6)	.040 (1.02)

NOTES:

- 1. UL LISTED AND CSA CERTIFIED FOR:
 A. SOLID OR STRANDED COPPER WIRE
 B. 302° F (150° C) MAX. TEMP. RATING
- 2. MATERIAL:
 A. STAMPING COPPER, TIN PLATED
- 3. See www.panduit.com FOR PART NUMBER SUFFIX DESIGNATION FOR PACKAGE SIZE.
- 4. DIMENSIONS IN BRACKETS ARE IN MILLIMETERS
- 5. INSTALLATION TOOLS:


A. UL LISTED AND CSA CERTIFIED: CT-100, CT-100A, CT-200, CT-570, CT-600A, CT-1570, CT-1701, CT-2500

- B. PANDUIT APPROVED: CT-160, CT-260
- 6. WIRE STRIP LENGTH: 9/32 *1/32 (7.1 *.8 _0)



LISTED 587H E52164







07	8-11	SHOR		MODIFIED NOTE #3	CORP. TINLEY PARK, ILLINOIS	
06	4-11	SB		ADDED CT-2500, CT-600A, CT1701 TOOLS. ADDED NOTE #3	NON-INSULATED BUTT SPLICE	
REV	DATE	BY	СНК	DESCRIPTION	DRAWN BY CHK'D SCALE NONE A41338	